



## *Florida Department of Transportation*

**RICK SCOTT  
GOVERNOR**

1109 S. Marion Avenue  
Lake City, Florida 32025-5874

**JIM BOXOLD  
SECRETARY**

April 27, 2015

To: Prospective Bidders

**Addendum No.: 2, E2U22, Financial Project # 41801267201  
Repaint the canopy structure over the vehicle/equipment washing  
facility at the FDOT Maintenance Office in St. Augustine, FL**

Please see below for the Department's answers in regards to the technical questions submitted.

### QUESTION AND ANSWER:

Question: Does the painting specification for this project exclude all other items listed in section 560 and 561 with the exception of 561-10&11?

Answer: The portions of the Standards Specifications included in this contract are described in the contract documents including, but not limited to, the scope of work, bid documents, non-technical specifications, addendum(s), etc.

Question: According to 561-10.3 requires a engineered designed, signed, and sealed containment plan, is this a requirement for this project?

Answer: The contractor must comply with Standard Specifications section 561-10.3.

Question: Is SSPC QP 1 and/or QP 2 certification required for this project per Section 561-5.1.

Answer: The Department will require the contractor to have SSPC QP 1 and SSPC QP 2 certifications.

Question: Are the only Quality Control/ Quality Assurance requirements those listed on page 5 of the invitation to bid?

Answer: The contractor must comply with all contract documents.

You must sign, date and fax a copy of this addendum back to me to indicate receipt.

All BIDDERS must acknowledge receipt of this addendum on the first page of the BID PROPOSAL in the space provided.

---

Company Name

---

Date

---

Signature

Thank you,

Jim Brown  
District Contracts Administrator  
Phone: 386-758-3798  
Fax: 386-758-3791